



John J. Wills, P.E. CPESC
President

Wills Burke Kelsey Associates, Ltd.
116 West Main Street, Suite 201 St. Charles, Illinois 60174
TEL: (630) 443-7755 FAX: (630) 443-0533
www.wbkengineering.com

Mediating the Built and Natural Environments

From: "John Wills" <JWills@wbkengineering.com>
Date: Oct 8, 2012 4:07 PM
Subject: RE: Neslund question RE: Addendum No 1 to Reynolds East District Tile Replacement Phase I
To: "Laura Ross" <rrdd2clerk@gmail.com>

No testing but manufacturer's certification required that the products meet the applicable specifications will be required before payment.

 [Follow us on LinkedIn](#)

The information contained in this e-mail is intended only for the individual or entity to whom it is addressed and should not be opened, read or utilized by any other party. This message shall not be construed as official project information or as direction except as expressly provided in the contract document. Its contents (including any attachments) may contain confidential and/or privileged information. If you are not an intended recipient you must not use, disclose, disseminate, copy or print its contents. If you receive this e-mail in error, please notify the sender by reply e-mail and delete and destroy the message

Date: Oct 8, 2012 2:35 PM
To: "Laura Ross" <rrdd2clerk@gmail.com>

The spec calls out "testing" on this project. What testing could be required on this project. Please verify that there will be no testing required on the pipe or the structures.